



## Report of Analysis

Client: Pathfinders Lubricants  
37 Harrison Ave.  
Aurora, Ontario  
L4G 1E2  
Canada

Lab Report no.: **CA120-6840**  
Report date: December 11, 2009

From: Pathfinders Lubricants, Aurora  
Submitted on: December 8, 2009  
Tested on: December 9, 2009  
Customer Product  
Description: Diesel fuel treated with Trijet  
Sample identification: Diesel fuel treated with Trijet

Attention: Jeremy Olson

TESTS	UNITS	METHODS	SPECIFICATIONS <sup>(1)</sup>	RESULTS
Lubricity- Fluid Temperature	°C	ASTM 6079	---	59.9
Major Axis	mm			0.23
Minor Axis	mm			0.14
Wear Scar Diameter	um			190

(1) Specifications not provided by the client

For   
Iftikhar Chughtai, Laboratory Manager

The information contained herein is based on laboratory tests and observations performed by Intertek Caleb Brett. This sample (or these samples) was or were submitted by the client solely for testing. Intertek Caleb Brett disclaims any and all liability for damage or injury which results in the use of the information contained herein; and nothing contained herein shall constitute a guarantee, warranty or representation by Intertek Caleb Brett with respect to the accuracy of the information, the sample, products or items described, or their suitability for use for any specific purpose. This report is for the exclusive use of the client and may only be reproduced in full by written permission of Intertek Caleb Brett. Unless otherwise instructed, all samples pertaining to this report will be discarded 45 days after the issuing date of this report.

**Intertek Caleb Brett**

651 Burlington Street East, Hamilton, Ontario, Canada L8L 4J5  
Telephone 905-529-0090 Fax 905-529-5989 e-mail [Iftikhar.chughtai@intertek.com](mailto:Iftikhar.chughtai@intertek.com)